## AMENDMENTS TO THE 2021 INTERNATIONAL FUEL GAS CODE (IFGC)

Note: Refer to the section "Common to all adopted 2021 International Codes" for more information.

<b>101.1 Title</b> [NAME OF JURISDICTION] Douglas County Building Division	Replace Insert
<b>103.1</b> [INSERT NAME OF DEPT] Douglas County Building Division	Replace Insert
113 Means of appeal	Delete in its entirety
114 Board of Appeals	Delete in its entirety
115.4 Violation penalties	Delete in its entirety

## 116.4 Failure to comply

Any person who shall continue any work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

**Delete section and substitute** 

303.3(3) and (4) Prohibited locations	Delete in their entirety
<b>404.12 Minimum burial depth</b> Underground piping systems shall be in (457 mm) below grade.	<b>Delete and substitute</b> Installed at a minimum depth of eighteen (18) inches
404.12.1 Individual outdoor appliances	Delete in its entirety
406.4.1 Test pressure	Delete and substitute
406 4.1 Test measure and demotion	

#### 406.4.1 Test pressure and duration

Low pressure gas piping systems not exceeding six (6) inches of water column shall be tested at ten (10) pounds per square inch on a thirty (30) pounds per square inch gauge using air, CO2, or Nitrogen for not less than fifteen (15) minutes with no perceptible drop in pressure. For welded piping, and for piping carrying gas at pressures in excess of fourteen (14) inches (356 mm) water column pressure, the test pressure shall not be less than sixty (60) pounds per square inch (413.4 kPa) and shall be continued for not less than thirty (30) minutes with no perceptible drop in pressure.

406.4.2 Test duration	Delete in its entirety
501.8 (8) Appliances not required to be vented	Delete in its entirety
<b>603.1 General</b> Log lighters are prohibited.	Delete in its entirety and substitute

# 621 Unvented room heaters

# Delete section in its entirety and substitute

Unvented room heaters and unvented fireplaces are prohibited within dwellings. (See clarification in the IRC amendments).