



**IRC Section R905.2.8.3 Sidewall Flashing** – Base flashing against a vertical sidewall shall be continuous or step flashing and shall be a minimum of 4” in height and 4” in width and shall direct water away from the vertical sidewall onto the roof and/or into the gutter. Where siding is provided on the vertical sidewall the vertical leg of the flashing shall be continuous under the siding.

When replacing an existing roof, Douglas County requires the kicked out portion to extend vertically a minimum of 1” above the shingle surface.